

CERTIFIKAT

No. 012 – SDG – 5 – 34 01 27



Thermal insulation – Product Group Isover G-33-F

Certificate holder/Issued for

Saint-Gobain Isover AB
Box 501, S-260 50 Billesholm, Sverige

Manufacturer/Factory

Saint-Gobain Isover AB, Billesholm

Product name and description

Thermal insulation made of mineral (glass) wool with facing of paper.
Thermal conductivity, declared value λ_D : 0,033 W/(mK). Fire classification: Euro class F

Product name: Takfotsskiva P 33, 20 mm and Skiva P 33, 20-120 mm.
Designation code: MW – EN13162 – T3 – MU1 – WS

Above mentioned products can also be manufactured with a variety of dimensions under the name: Isover Specialisolering G-33-F.

Certificate

Products mentioned above are found to comply with requirements in EN 13162:2001 with corrigendum AC and the SDG-5 Key-mark Rules. The manufacturer is found to comply with requirements in EN 13172:2001

Marking

Products conforming to this certificate shall be marked in accordance with the requirements in the Key-mark.


Validity

This certificate was first issued on 4th July 2003 and is valid as long as the conditions in the standard are fulfilled and the standard is not modified significantly. The validity of the certificate can be checked on www.key-mark.org.

Borås 17th October 2006

SP Swedish National Testing and Research Institute
Certification


Lennart Månsson
Certification Manager


Ingvar Sahlin
Technical Officer

SP Swedish National Testing and Research Institute

Postal address Phone / Fax Reg. number E-mail / Internet
SP +46 33-16 50 00 556464-6874 info@sp.se
Box 857 +46 33-13 55 02 www.sp.se
SE-501 15 Borås
SWEDEN

This certificate may not be reproduced other than in full, except with the prior written approval by SP.