


# CERTIFIKAT

No. 012 – SDG – 5 – 34 01 39



## Thermal insulation – Product Group Isover G-36-E

**Certificate holder/Issued for**

**Saint-Gobain Isover AB**

Box 501, SE-260 50 Billesholm, Sverige

**Manufacturer/Factory**

Saint-Gobain Isover AB, Billesholm

**Product name and description**

Thermal insulation made of mineral (glass) wool with facing of flame retarded paper

Thermal conductivity, declared value  $\lambda_D$ : 0,036 W/(mK).

Fire classification: Euroclass F

Product name: Skiva SP 36, 45-220 mm

Designation code: MW – EN13162 – T2 – MUI

Above mentioned products can also be manufactured with a variety in dimensions under the name: Isover Specialisolering G-36-E

### Certificate

Products mentioned above are found to comply with requirements in EN 13162:2001 with corrigendum AC and the SDG-5 Key-mark Rules. The manufacturer is found to comply with requirements in EN 13172:2001.

### Marking

Products conforming to this certificate shall be marked in accordance with the requirements in the Key-mark.

### Validity


This certificate was first issued on 10<sup>th</sup> October 2006 and is valid as long as the conditions in the standard are fulfilled and the standard is not modified significantly.

The validity of the certificate can be checked on [www.key-mark.org](http://www.key-mark.org).

Borås 10<sup>th</sup> January 2007

**SP Swedish National Testing and Research Institute**  
Certification

  
Lennart Månsson  
Certification Manager

  
Lennart Aronsson  
Certification Officer

SP Swedish National Testing and Research Institute

Postal address

SP

Box 857

SE-501 15 Borås

SWEDEN

Phone / Fax

+46 33-16 50 00

+46 33-13 55 02

Reg.number

556464-6874

E-mail / Internet

[info@sp.se](mailto:info@sp.se)

[www.sp.se](http://www.sp.se)

This certificate may not be reproduced other than in full, except with the prior written approval by SP.