


# CERTIFIKAT

No. 012 – SDG – 5 – 34 01 21



## Thermal insulation – Product Group Isover G-41-A1

### Certificate holder/Issued for

**Saint-Gobain Isover AB**

Box 501, S-260 50 Billesholm, Sverige

### Manufacturer/Factory

Saint-Gobain Isover AB, Billesholm

### Product name and description

Thermal insulation made of mineral (glass) wool with or without facing of staple tissue Thermal conductivity, declared value  $\lambda_D$ : 0,041 W/(mK). Fire classification: Euroclass A1

Product name: Rulle 41, 30-220 mm.

*Designation code: MW – EN13162 – T1 – MU1*

Product name: Skiva 41, 30-220 mm and Regelskiva 41, 45-220 mm

*Designation code: MW – EN13162 – T2 – MU1*

Product name: Piano® Ljudskiva c450, 30-120 mm, Piano® Ljudskiva/Rulle c600, 30-120 mm and Piano® Ljudrulle c450, 30-120 mm

*Designation code: MW – EN13162 – T2 – MU1 – AF,6*

Above mentioned products can also be manufactured with a variety of dimensions under the name: Isover Specialisolering G-41-A1.

### Certificate

Products mentioned above are found to comply with requirements in EN 13162:2001 with corrigendum AC and the SDG-5 Key-mark Rules. The manufacturer is found to comply with requirements in EN 13172:2001

### Marking

Products conforming to this certificate shall be marked in accordance with the requirements in the Key-mark.


### Validity

This certificate is a revised version of a previous document with the same number dated 27<sup>th</sup> October 2006 and is valid as long as the conditions in the standard are fulfilled and the standard is not modified significantly. The validity of the certificate can be checked on [www.key-mark.org](http://www.key-mark.org).

Borås 15<sup>th</sup> December 2006

**SP Swedish National Testing and Research Institute**  
Certification

  
Lennart Månsson  
Certification Manager

  
Ingvar Sahlin  
Technical Officer

SP Swedish National Testing and Research Institute

Postal address Phone / Fax Reg. number E-mail / Internet  
SP +46 33-16 50 00 556464-6874 info@sp.se  
Box 857 +46 33-13 55 02 www.sp.se  
SE-501 15 Borås  
SWEDEN

This certificate may not be reproduced other than in full, except with the prior written approval by SP.