



Appendix 4 to
CERTIFIKAT
0402 - CPD - SC0480-10

Dated 26th October 2011

Thermal insulation products for building equipment and industrial installations – Factory made mineral wool (MW) products

Product group: G100

Thermal insulation made of mineral (glass) wool. Facing: U = unfaced, S = glass tissue.

Density range: $\geq 100 \text{ kg/m}^3$

Designation code: MW-EN 14303-T3-ST(+)**400**

Product name: G100-U, G115-U, G120-U, G120-S, G125-U, G125-S

Classification

Reaction to fire classification	A2-s1,d0
Mean temperature °C	Declared thermal conductivity W/m°C
10	0,033
50	0,036
100	0,040
150	0,046
200	0,054
250	0,062
300	0,073
350	0,085
400	0,098

Appendix to Certificate issued by Notified Body No. 0402, page 1(1) Signed by SP:

SP Technical Research Institute of Sweden

Postal address Phone / Fax Reg.number E-mail / Internet
SP +46 10 516 50 00 556464-6874 info@sp.se
Box 857 +46 33 13 55 02 www.sp.se
SE-501 15 Borås
SWEDEN

Swedish Notified Bodies are appointed by SWEDAC, the Swedish Board for Accreditation and Conformity Assessment, under the terms of Swedish legislation.
This certificate may not be reproduced other than in full, except with the prior written approval by SP.