



Centrum stavebního inženýrství a.s. Praha
Centre of Building Construction Engineering Prague
Akreditované zkušební laboratoře, Autorizovaná osoba,
Oznámený subjekt, Certifikační orgán
Accredited Test Laboratories, Authorised Body,
Notified Body, Certification Body
Pražská 16, 102 00 Praha 10



CERTIFICATE OF CONSTANCY OF PERFORMANCE

1390 – CPR – 0306/11/P

In compliance with the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Factory made mineral wool product used for thermal insulation of buildings

Trade mark	Thermal conductivity $W.m^{-1}.K^{-1}$	Reaction to fire	Type code according EN 13 162
Brand/Lastskiva 140	0,037	A1	MW-EN 13162-T4-MU1-CS(10)25-WS
S 130-S			

produced by : **Saint-Gobain Construction Products CZ a.s.**
Počernická 272/96
108 03 Praha 10, Česká Republika

IČ : **250 29 673**

**and produced in the
manufacturing plant** : **Saint-Gobain Construction Products CZ a.s.**
Masarykova 197
517 50 Častolovice, Česká republika

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 13 162:2012

under system 1 for the performances set out in this certificate are applied and that
the construction products fulfil all the prescribed requirements for these performances

This certificate was first issued on 01. 08. 2011 as a certificate pursuant to CPD and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performances of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.

Notified Body 1390
Prague, 05. 06. 2014




Ing. Petr Kučera, CSc.
Deputy of Notified Body 1390